

Requirements for Receiving Bulk Water

- Customers must either pre-pay or set up an account at Town Hall
(All water must be received in a single day)
- Customers must supply their own hose
- The Town has a limited supply of fittings for hoses including:
 - 2.5" Male Standard Firefighter threads
 - 2" Male Cam-Lock
 - 1.5" Male Firehose threads
 - 1.5" Male NPT Threads
- Customers must supply any fitting not listed that is needed for filling
- Customers must also supply a fill pipe with minimum of a 6" Air Gap that is permanently attached to the Tank

What is an Air Gap?

- An Air Gap is a physical disconnect from the filling pipe and the tank being filled.

